



ASTM D1785 Schedule 80 Pipe Certification

To Whom It May Concern:

Please be advised that the North American Pipe Corporation pipe products:

ASTM D1785 Solvent Weld Belled End PVC Distribution Pipe, Sizes ½"-12" Sch 80

Provided by North American Pipe Corporation is manufactured in accordance with the following standards:

ASTM D1785 Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe, Schedules 40, 80, and 120

ASTM D2672 Standard Specification for Joints for IPS PVC Pipe Using Solvent Cement

The PVC material conforms to a cell classification of 12454 as defined by ASTM D1784 Standard Specification for Rigid Poly(Vinyl Chloride) (PVC) Compounds. The standard pipe laying lengths are 20 feet. The pipe is listed by NSF International to ANSI/NSF 14 and ANSI/NSF 61.

Mike Glasgow, P.E.
Engineering and Field Services

Quality Piping Materials