



AWWA C900-07 PVC Pipe for Reclaimed Water Applications Certification

To Whom It May Concern:

ANSI/AWWA C900-07 PVC Water Distribution Pipe, Sizes 4"-12", DR25 (Pressure Class 165 psi), DR18 (Pressure Class 235 psi), and DR14 (Pressure Class 305 psi) provided by North American Pipe Corporation is manufactured in accordance with the following standards:

AWWA C900-07 Standard for Polyvinyl Chloride (PVC) Pressure Pipe and Fabricated Fittings, 4 In. Through 12 In. (100 mm Through 300 mm), For Water Distribution

ASTM F477 Standard Specification for Elastomeric Seals (Gaskets) for Joining Plastic Pipe

ASTM D3139 Standard Specification for Joints for Plastic Pressure Pipes Using Flexible Elastomeric Seals

The PVC material conforms to a cell classification of 12454 as defined by **ASTM D1784 Standard Specification for Rigid Poly(Vinyl Chloride) (PVC) Compounds and Chlorinated Poly(Vinyl Chloride) (CPVC) Compounds..**

The products are colored purple when specified for reclaimed water applications. Pipes manufactured for reclaimed water applications (purple colored) are not listed by **Underwriters Laboratories, Factory Mutual, or NSF International.**

The standard pipe laying length is 20 feet. Product in 14 foot length is available on request.

If you have additional questions please contact me. My mobile number is (281) 658-9763 and my e-mail is mglasgow@northamericanpipe.com.

Mike Glasgow, P.E.
Engineering and Field Services

Quality Piping Materials